VISION OF ENVIRONMENTAL HEALTH
-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 16 Regency Block D PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

3) 0-12 e Disp Sbk .03
12-36 c wpvp 2 wk capacity PS
36-72 c vp

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
	0-15	SCL WSBK	FRI SSSP					PS
	15-30	RC SBK	FR SP					.3
	30-56	RCL WSBK	FRI SP					
	0-4	BSL GR	FRI SSSP					PS
	4-40	RC ABK	FR SP	Redox @ 28"				.2-.25
	40-56	CL WSBK	FRI SSSP					
	0-14	RC SBK	FRI SSSP					PS
	14-60	CL WSBK	FRI SSSP	Many SAP				.3-
	0-26	RC SBK	FRI SSSP					PS
	26-42	CL WSBK	FRI SSSP					.3
	42-60	SCL SP						

DESCRIPTION		
Available Space (.1945)		
System Type(s)		
LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____