IREDELL COUNTY HEALTH DEPARTMENT STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 166678 PIN # 4637 00 8594 DATE May 27, 2011

OWNER or APPLICANT Greg Anderson PHONE: Business Home:

OWNER or APPLICANT ADDRESS 133 Vista Bluff Lane

LOCATION / DIRECTIONS Brawley School Rd TR Blume TL Beaten Path TL Vista Bluff 3rd on Left

SUBDIVISION Vista Bluff BLOCK / SECTION LOT # 3 LOT AREA .718 Ac. DESIGN FLOW 360gpd L.T.A.R. .3 gpd/ft²

Septic Tank 5 Existing Gallons: STB Date

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 1 ★ Linear Feet 50 ★

Trench Width 24" Max. Trench Bottom Depth 36" Gravel Depth NA ☒ GRAVITY ☐ PRESSURE

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: T+J Panel

Repair System Description: T+J Panel LP

Maintenance Agreement Required ☐ YES ☒ NO

☒ Residence No. Bedrooms 3 ☐ Business No. Persons ☐ Other No. Employees ☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions ★ 5 lines and 200' Total
- Properly abandon per H.D. existing system w/in 15 ft. of pool - 50 ft. Total

Comments / Conditions Everything Checked 6/7/11

INITIAL SITE SKETCH

- Outside wall of pool shall be staked at time of final inspection
- Remove Drop Boxes and replace with D-Box and one flow divider to two 25' lines as per plan
- Irrigation water line is damaged and is to be re-routed along property line at rear
- Repair may need Trench modification per T+J
- No vehicles are to be driven over corner of driveway that covers drainline

Follow Plan from SAME
Approved by ICHD
- Relocating System for Pool -

Preconstruct Meeting with Health Dept. Required

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: [redacted] Date 5-31-11

Improvement Permit by: Cindy Melvill REHS Date 5-27-11

Authorization to Construct by: Cindy Melvill REHS Date 5-27-11

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: RS

Operation Permit by: Date: 6/7/11

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant