DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: DAVID T. MARTIN INC APPLICATION DATE 7-15-04
ADDRESS: PO BOX 6105 STATESVILLE 28687 DATE EVALUATED: 7-28-04
PROPOSED FACILITY: 3BR PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .69
LOCATION OF SITE: PROPERTY RECORDED:
WATER SUPPLY: ❑ Private ❑ Public ❑ Well ❑ Spring ❑ Other VISTA BLUFF LOT 2
EVALUATION METHOD: ❑ Auger Boring ❑ Pit ❑ Cut
TYPE OF WASTEWATER: ❑ Sewage ❑ Industrial Process ❑ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L	0-6	wk sbk scl	vfr ss/p sexp	—	>48	—	—	PS .3
		6-48	mo sbk c	fr s/p					
2	L	0-6	wk sbk scl		—	>48	—	—	PS .3
		6-48	mo sbk c	fr s/p sexp					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Pump 50%	50% LPP
Site LTAR	.3	.3

OTHER FACTORS (.1946): NO
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: CS
OTHER(S) PRESENT: Julie Smith

COMMENTS: