DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: APPLICATION DATE
ADDRESS: DATE EVALUATED: 7-28-04
PROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE:
LOCATION OF SITE: PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other VISTA BLUFF LOT 1
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L	0-6	wk sbk scl		—	40	~~ps~~	—	ps .3
		6-24	mo sbk c	fr s/p sexp					
		24-40	mo sbk c+sap	fr s/p ↓					
		40-48	sl ma sap	sl					
2	L	0-15	wk sbk l		—	>48	ps	—	ps .3
		15-48	mo sbk c	fr s/p sexp					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	ps	ps
System Type(s)	50% Gravity	LPP 50%
Site LTAR	.3	.3

OTHER FACTORS (.1946): NO
SITE CLASSIFICATION (.1948): ps
EVALUATED BY: CS
OTHER(S) PRESENT: Julie Smith

COMMENTS: