HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 2L-A-13 (PT)
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: HOME VENTURE OWNER: AGENT: PHONE: 376-7600
ADDRESS: P.O. Box 37179 APPLICATION DATE: 7-25-96 DATE EVALUATED: 8-17-96
CHARLOTTE, NC PROPOSED FACILITY: 4BR HOUSE W/ BASEMENT
PROPERTY SIZE: 0.6991
LOCATION OF SITE: SHANEAR'S BLUFF I-C #15
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	L 15%	0-18	C	MMSBK	1:1 / SS / FI P	1942 WETNES CONDITION	S
		18-48	CL	WSBK	1:1 / FR / SS / SP	1943/ 1956 SAPROLITE	PS
						1944 RESTRICTIVE HORIZON	S
						1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.3
2	L 12%	0-20	C	MMSBK	1:1 / FI / SS / P	1942 WETNES CONDITION	S
		20-48	CL	WFSBK	1:1 / FR / SS / SP	1943/.1956 SAPROLITE	PS
						1944 RESTRICTIVE HORIZON	S
						1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.3
3	L 10%	0-20	C	MMSBK	1:1 / FI / SS / P	1942 WETNESS CONDITION	S
		20-48	CL	WMSBK	1:1 / FR / SS / SP	1943/.1956 SAPROLITE	PS
						1944 RESTRICTIVE HORIZON	S
						1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.3
4						1942 WETNESS CONDITION	
						1943/.1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						1942 WETNESS CONDITION	
						1943/.1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.3
OTHER FACTORS(.1946) NONE SYSTEM TYPE CHAMBERED, PUMP-FED
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT JAY LAWRENCE
COMMENTS: