HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 2L-A-13 (PT)
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: HOME VENTURE OWNER: AGENT: PHONE: 376-7600
ADDRESS: P.O. Box 37174 APPLICATION DATE: DATE EVALUATED: 8-17-96
CHARLOTTE, NC PROPOSED FACILITY: 4BR HOUSE W/C.S.
PROPERTY SIZE: 0.6764 ACRE
LOCATION OF SITE: SHUMENDERS BLUFF I-C #5
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	L 6%	0-6	SL	GR	1:1 / VFR	.1942 WETNES CONDITION S
		6-48	CL/SaC	SBK	1:1/FR/SS	.1943/.1956 SAPROLITE PS
						.1944 RESTRICTIVE HORIZON 3
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3
2	L 6%	0-8	SL	GR	1:1 / VFR	.1942 WETNES CONDITION S
		8-24	C	SBK	1:1 / FR	.1943/.1956 SAPROLITE PS
		24-48	CL/SaC	SBK	1:1 / FR/SS	.1944 RESTRICTIVE HORIZON 3
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1948): S SITE LONG-TERM ACCEPTANCE RATE 0.3 GPD/FT
OTHER FACTORS(.1946) NONE SYSTEM TYPE PPBPS, GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT JAY LAWRENCE
COMMENTS: