463702 2383

13438

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Edward Allender DATE Sept. 27, 91 PERMIT NO. 21-4-A-109

PHONE: Business _____ Home _____

LOCATION 1100 TR 1178 (Blume) TR 1443 (Beaten Path) ~½ mile TR Whittier Lane at end S. R. No. _____

SUBDIVISION NAME Crescent - LAKE NORMAN LOT NO. 109 SECTION OR BLOCK NO. 9

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2-3

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site ~~Suitable~~ PS	Yes	(✓)	No	( )	

Character & Porosity of Soil PS clay
Percolation Rate 2.3
Topography rolling
Depth to Water Table 4'+
Rock or other impervious formations none obs.

Lot Area Existing

~~Basement with Plumbing~~ Basement without Plumbing ____ No Basement



Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. _____ Linear Ft. 200'
Depth of Stone in Lines 16" panel block
Water Supply: Individual (✓) Public ( )

TO SR 1443

Driveway
Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Edward Allender

IMPROVEMENTS PERMIT BY D box w/ speed levelers David R. Hinson, RS.

COMMENTS: Old system can be used for bathroom in garage. Follow contour with new drainfield. 34" maximum trench bottom depth.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold