1130 11.00

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Phillip W. Ball DATE 8-31-84 PERMIT NO. 234

PHONE: Business _____ Home _____


LOCATION 1160 IR 1178 IR 1443 & About 3/4 mile IR Whittier Lane at end ON R S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 1522 SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	95 MPI 24 hrs	
Auto. Wash. Machine	Yes (X)	No ( )	Topography	Level	
Site Suitable	Yes (X)	No ( )	Depth to Water Table		
Lot Area 20,000 FT²			Rock or other impervious formations	NONE OBS.	



Size of Tank 1000 Gals.

Nitrification Field: 4

No. of Lines 4

Sq. Ft. 1080 Linear Ft. 360

Depth of Stone in Lines 12"

Water Supply: Individual (X)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: X Phillip W Ball

Plot of System

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Stay at least 15' from drain with Septic Field. Use good quality effluent pump + high WATER ALARM

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold