4637023118

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Cathey Construction DATE 5-4-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 TR 1178 (Blume) TR 1443 past jct w/ 1444 (Beaton Path) 1st home on left S. R. No. _____

SUBDIVISION NAME L.V. LOT NO. 1532 SECTION OR BLOCK NO. 9

House (✓) Mobile Home ( ) Business ( ) Other Remodeling inside and enlarging existing room w/ Addition

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil _____

Percolation Rate _____


Topography _____

Depth to Water Table _____

Rock or other impervious formations _____

Lot Area Existing

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Asbury Circle

Size of Tank Existing Gals.

Nitrification Field:

No. of Lines EXISTING

Sq. Ft. _____ Linear Ft. _____

Depth of Stone in Lines _____

Water Supply: Individual ( )

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Existing system OK at time of inspection.

Original permit issued in name of Janet Simril (7-8-86)

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: J. R. Hinson, R.S. DATE 5-4-87

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Janet Simril DATE 7-8-86 PERMIT NO. 394

PHONE: Business _____ Home _____

LOCATION 1100 TR 1178 TL 1443 Past Beaten Path
left on Amsbury circle on left. S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 1532 SECTION OR BLOCK NO. 9

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area .95 acres

Character & Porosity of Soil Clayey
Percolation Rate .4
Topography 6 to 10%
Depth to Water Table 4'+
Rock or other impervious formations none

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 1350 Linear Ft. 450
Depth of Stone in Lines 16 to 20"
Water Supply: Individual (✓)
Public ( )

Installed by Bobby Mayhew mason Co.
I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: lay-out had to be altered original lines were with in 50' of lake They were cut off & Bet system installed as shown. J. C. Moore

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 7-8-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

4pm

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Janet Smirl DATE 7-3-86 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 TR 1178 TL 1443 Past Beaten Path left on Amsbury Circle on left S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 1552 SECTION OR BLOCK NO. 9

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area .95 acre

Character & Porosity of Soil Clay
Percolation Rate 14
Topography 6 to 10 %
Depth to Water Table 4'+
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 1350 Linear Ft. 450
Depth of Stone in Lines 16 to 20"
Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: ✓Wayne Broome

lay-out replaces one made 2-6-86

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Drain lines were within 50' of Lake high water mark

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold