4637039609

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jack Rankin DATE 4-21-78 PERMIT NO. 63

PHONE: Business _____ Home 872-6952

LOCATION 1120 TR on 1128 about 1/2 mile

S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 146 SECTION OR BLOCK NO. 5

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	40 min/in	
Auto. Wash. Machine	Yes ( )	No (✓)	Topography	Rolling	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6' to 5'	
			Rock or other impervious formations	None	

Lot Area 1 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Robinson Backhoe

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Robert Evans Farmer DATE 4-21-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold