4637111772

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Duncan McCuffie DATE 5-25-83 PERMIT NO. 164

PHONE: Business _____ Home _____

LOCATION #100 TR 1178 TL 1443 TR 1239 (Cultpepper Drive) 2nd house on left S. R. No. _____

SUBDIVISION NAME LAKE NORMAN LOT NO. 132 SECTION OR BLOCK NO. 9

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (X) No ( )

Auto. Dishwasher Yes (X) No ( )

Auto. Wash. Machine Yes (X) No ( )

Site Suitable Yes (X) No ( )

Lot Area 2 3/4 Acre


Character & Porosity of Soil Clay loam

Percolation Rate 0.8 gal/ft²/day

Topography 4 60 40 4+

Depth to Water Table _____

Rock or other impervious formations NONE OBSERVED



Plot of System

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1080 Linear Ft. 360
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public " ( )

Installed by Chero-Grove Septic Tank Service John Barnhardt

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY O.R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 5-25-83

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold