IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Northwood Cedar Homes DATE 6/24/88 4637-17-2091 PERMIT NO.

PHONE: Business (704) 878-5206 Home

LOCATION 150 W TL 1168 (McCrary Rd.) 1/8 - 1/4 mile TR Private Road near end on Right. S. R. No.

SUBDIVISION NAME Hidden Harbour LOT NO. 2 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	( )	No	( )

Character & Porosity of Soil clay
Percolation Rate n. 4 gpd/ft²
Topography 2-6%
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area

(✓) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement



Plot of System NOT TO SCALE

1250 pumptank
Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public ( )

Installed by F J ERVIN

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY ACP

COMMENTS: Alarm cked. ✓

CERTIFICATE OF COMPLETION BY Andie C. Green DATE 6/24/88

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold