207

07586

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Northwood Cedar Homes DATE Nov. 4'87 PERMIT NO. _____

PHONE: Business (704) 898-5206 Home _____

LOCATION 150W N 1168 (McCrary Rd.) 1/8-1/4 mile TR private road, near end on Lt. S. R. No. _____

SUBDIVISION NAME Hidden Harbor LOT NO. 2 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes ( ) No ( )

Lot Area ~20000 ft²

Character & Porosity of Soil clay

Percolation Rate 2.4


Topography 2-6%

Depth to Water Table 4'+

Rock or other impervious formations none obs.

1250 gal pump tank

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 200 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Lake

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Michael Talbert

IMPROVEMENTS PERMIT BY David R. Hinson, R.S.

COMMENTS: Follow contour w/drainfield. Construct drainfield with 12"-18" cover over stone. Pressure dose conventional field by using a ball valve at the head of each ditch with a 1¼" pipe down the center with one 5/32" hole drilled every 5 feet (2" pressure head/ditch)

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: *5/26/88 See note DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold