4637217747

IREDELL COUNTY HEALTH DEPARTMENT

11257

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert A Joyner DATE 2/4/91 PERMIT NO. 2L-5-A-170

PHONE: Business ________ Home 373-3262

LOCATION SR 1240; 1100 TR 1178 TR 1240, 1/2 mile on (L)

S. R. No. 1240

SUBDIVISION NAME Crescent LOT NO. 170 SECTION OR BLOCK NO. 9

House (✓) Mobile Home ( ) Business ( ) Other ________

No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 20,000

Character & Porosity of Soil EXISTING SYSTEM


Percolation Rate

Topography

Depth to Water Table

Rock or other impervious formations

____ Basement with Plumbing ✓ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by ________

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: ________

IMPROVEMENTS PERMIT BY ________

COMMENTS: No visible evidence of malfunction on this date. S/T and drainfield should not be buried under fill material during construction.

CERTIFICATE OF COMPLETION BY ________ DATE ________

EXISTING SYSTEM CHECKED BY: Wesley Sparks R.S. DATE 2/4/91

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Joyner DATE 10-23-86 PERMIT NO. 563

PHONE: Business _____ Home _____

LOCATION 1100 TR 1178 (Blane) TR Pattersville ~1 mile on left

S. R. No. _____

SUBDIVISION NAME L.N. LOT NO. 1586 SECTION OR BLOCK NO. 9

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1


Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil clay
Percolation Rate 45
Topography 8-10%
Depth to Water Table 4FT
Rock or other impervious formations none obs.

Lot Area 1.2AC

LAKE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public ( )

Installed by Richard Abernethy

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY KLS

COMMENTS: _____

CERTIFICATE OF COMPLETION BY D R Hinson, R.S. DATE 10-23-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

2800

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Joyner DATE 3/4/86 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Bradley School Rt on Blume, Rt on Patterneck, 1/2 mile on Lf / S. R. No. _____

SUBDIVISION NAME Crescent L & T LOT NO. 1506 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area @ 1.15 acres

Character & Porosity of Soil cl/loam-cl
Percolation Rate 0.5 gpl/ft2 (Eval by Fred Clemmer)
Topography 6-10%
Depth to Water Table 4'+
Rock or other impervious formations None Noted

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 x Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 220 Linear Ft. 240 x
Depth of Stone in Lines 12" x
Water Supply: Individual (✓) To be Drilled
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Robert A Joyner

IMPROVEMENTS PERMIT BY _____

COMMENTS: System must go in area designated or will have to use pumping system/ Keep well 50' minimum from this area!!

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold