4637252689

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Patricia Smith DATE 8-24-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 150 W. TL 1168 (McCrary) TL 1225 (Riverwood) on Rt. after road ~~towards~~ turns to dirt. S. R. No. _____

SUBDIVISION NAME L.N. LOT NO. 1160 SECTION OR BLOCK NO. 10

House (✓) MODULAR HOME Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Clay
Percolation Rate ~4
Topography 6-10%
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area ~3/4 Acre

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System NTS

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. _____ Linear Ft. 150' of
Depth of Stone in Lines 16" T&J Panels
Water Supply: Individual (✓)
Public ( )

Installed by F.J. ERVIN

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew C Green DATE 8-24-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Patricia Smith DATE Mar. 27, 87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 150 W. TL 1168 (McCreary) TL 1225 (Riverwood) on Rt after road turns to dirt S. R. No. _____

SUBDIVISION NAME L.N. LOT NO. 1160 SECTION OR BLOCK NO. 10

Modular

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil clay
Percolation Rate ~ 1, 4
Topography 6-10%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

Lot Area ~ 3/4 Ac.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. _____ Linear Ft. 150' of 16" panels
Depth of Stone in Lines T & J

Water Supply: Individual (✓)
Public ( )

6" sand underneath

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Patricia Smith

IMPROVEMENTS PERMIT BY David R. Hunsucker, R.S.

COMMENTS: Keep system shallow (~6" cover over panels)

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold