IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thomas N. Crisp DATE 3-26-80 PERMIT NO. 54

PHONE: Business _____ Home _____

LOCATION 150W TL 1168 ~.6mile ON R

_____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)	Percolation Rate 80 min/in
Auto. Dishwasher	Yes	( )	No	(✓)	Topography 2-4%
Auto. Wash. Machine	Yes	(✓)	No	( )	Depth to Water Table UNKNOWN
Site Suitable	Yes	(✓)	No	( )	Rock or other impervious formations NONE OBSERVED

Character & Porosity of Soil Clay loam

Lot Area 1 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual (X)
Public ( )

Installed by J. J. Erwin

IMPROVEMENTS PERMIT BY David R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 3-26-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold