DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Nicholls APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 9/16-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
LOCATION OF SITE: Lot 27 ph 2 Edgewater PK. PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTA
1		0-14	gr-wk sbk sl	fr sss sp					≥3
		14-34	m sbk RC	fr sp sso					
		34-58	(B-C) wk sbk RC/L	fr sss sp common mi sap					
2	9% ±	0-8	gr brn sl	fr sp					≥3
		8-14	wk sbk brn sl	fr sss sp					
		14-23	wk sbk brn c	fr sp sso sp					
		23-47	m sbk RC	fr sp sso sp					
		47-52	wk sbk RCL	fr sss sp					
3		0-3	gr brn sl	fr sss sp					≥3
		3-16	m sbk RC	fr sss sp sso sp					
		16-43	(B-C) wk sbk RCL	fr sss sp					
		43-56	massive L/sl sap	fr sss sp					
4		0-13	m sbk RC	fr sss sp					≥3
		13-59	(B-C) wk sbk RCL	fr sss sp common mi sap					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	RS
System Type(s)	Brkn Conv.	25% Red
Site LTAR	≥3	3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): RS
EVALUATED BY: _____
OTHER(S) PRESENT: Wendell Crosby