IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mrs. A. Walters DATE July 11, '78 PERMIT NO. 153

PHONE: Business _____ Home _____

LOCATION 1100 T.L. on SR. 1178 T.L. on SR. 1240 at end on left

S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 184 SECTION OR BLOCK NO. 9

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1 AC.


Character & Porosity of Soil Cecil clay loam

Percolation Rate 5

Topography 4-6%

Depth to Water Table 6'+

Rock or other impervious formations none obs.



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 16"+

Water Supply: Individual (✓)

Public ( )

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY J. Houston

COMMENTS: 2-Tk system installed on lower line to compensate for 10" of fall.

CERTIFICATE OF COMPLETION BY Wendell Henson DATE July 11, '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold