VISION OF ENVIRONMENTAL HEALTH
N-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: _____ APPLICANT: _____
DDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6-4-01
ROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
OCATION OF SITE: Lot 40 Devonshire PROPERTY RECORDED: _____
VATER SUPPLY: ❑ Private ❑ Public ❑ Well ❑ Spring ❑ Other _____
VALUATION METHOD: ❑ Auger Boring ❑ Pit ❑ Cut
YPE OF WASTEWATER: ❑ Sewage ❑ Industrial Process ❑ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-9	gr brn sl/scl fr		Lagamount/surface rock				.3+
		9-26	sbk	rcl/cl fr sss/p sop					
		26-61	wk sbk	yr cl/l common mi sap fr ss/p					
2		0-8	gr brn sl/scl fr		lagamount/surface rock				.3+
		8-30	sbk	rcl fr sss/p sop					
		30-58	massive sl sap	fr ss-ns np					
3		0-6	gr wk sbk brn scl fr						.3
		6-23	sbk	rc fr sss/p sap					
		23-50	wk sbk	yr cl common mi sap fr ss/p					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____