DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jeff Dembiec APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 4/11/18
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: ___
LOCATION OF SITE: 474 Oak Tree Rd PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	AH-1	0-10"	Rd/Brw C w/SBK	SS,SP,SE,FR					PS .3
		10-48	Rd C	m-w/SBK SS,SP,SE,FI-FR					
2	AH-2	0-23	Brw C w/SBK	SS,SP,SE,FR					PS .25
		23-40	Rd C w/SBK	S,P,SE,FI					
		40-	R/C C/L SAP						
			few Low chroma		mottles around roots				
3	AH-3	0-8	Brw C/L FI SS,SP						.125 For Dy
		8-24	Brw SC w/SBK	SS,SP,FR					
		24-40	Rd/Brn C w/SBK	FR S,P					
		40-48	R/C R-C SC w/SBK	SS,SP					
			Common Inclus of	SAP & yell/brw/gray mtrx					
4		0-8	Brw C w/SBK	FR,SS,SP					.125
		8-38	Rd C w/SBK	FI-FR S,P to SS,SP					
		38-48	Yell/Brw C w/SBK	FI SS,SP					
			with low Chroma	mottles around roots					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___