IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Harold E Faggart DATE 5-20-96 PERMIT NO. _____

PHONE: Business 393-3472 Home _____

LOCATION Hoc TR on 1179 1½ mi on right S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 219 SECTION OR BLOCK NO. 7


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 3/4 acre

Character & Porosity of Soil Clay loam Porosity F.
Percolation Rate Not Taken
Topography 2-3% Slope
Depth to Water Table 6 to 8' to Lake Level
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 25
Depth of Stone in Lines 24"
Water Supply: Individual (✓)
Public ( )

Installed by T. A. Bowie

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 5-

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold