IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Keith Carpenter DATE 7-6-78 PERMIT NO. 149

PHONE: Business _____ Home 596-1137

LOCATION 150 w Jct on 1180 Jct on 1221

S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 31 SECTION OR BLOCK NO. 10

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Sandy Clay loam


Percolation Rate 45 min/in

Topography 5 to 8% Slope

Depth to Water Table 6' to 8'

Rock or other impervious formations None

Lot Area 3 acre +



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 1

Sq. Ft. 600 Linear Ft 200

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Washing Machine Line
9' + 33' = 300 sq ft

Installed by F. J. Sywin

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature] DATE 7-6-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold