4637342662

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Elliott Lynn DATE 7-21-14 PERMIT NO. 205

PHONE: Business _____ Home 782-6163

LOCATION 150 W. TL on 900 TR end Rt. Lot on Rt.

S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 32 SECTION OR BLOCK NO. 10

House ( ) Mobile Home (✓) Business ( ) Other Cabin W/ 4 bedrooms 2 baths

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sandy Clay loam Granite Fair
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	Not Tested
Auto. Wash. Machine	Yes ( )	No (✓)	Topography	2 to 5% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	5 ft min to Lake level
			Rock or other impervious formations	Some Saprock

Lot Area 1/2 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by E T Rush

IMPROVEMENTS PERMIT BY JC Blair

COMMENTS: Must be Easy Leather Cable and Septic Tank Risers

CERTIFICATE OF COMPLETION BY Jeff Lentz DATE 7-22-14

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Lima DATE 5-9-94 PERMIT NO. 128

PHONE: Business _____ Home 528-6107

LOCATION 150 West TL on 1120 TR next Rd To right 1mi on left S. R. No. 1505

SUBDIVISION NAME Lake Norman LOT NO. 32 SECTION OR BLOCK NO. 10


House ( ) Mobile Home (✓) Business ( ) Other Cabin with 1 bedroom + 1 bath

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	( )	No	(✓)
Auto. Wash. Machine	Yes	( )	No	(✓)
Site Suitable	Yes	(✓)	No	( )

Lot Area 3/4 acre

Character & Porosity of Soil Sandy Clay loam Porosity Fair
Percolation Rate Not taken
Topography Good slope
Depth to Water Table 4 ft to Lake Level
Rock or other impervious formations Possibility of rock Some Subsurface



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )
Well not shown

Installed by _____

IMPROVEMENTS PERMIT BY J. C. Morris

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold