IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR C. G. Overcash DATE 7-17-05 PERMIT NO. 216

PHONE: Business 732-2444 Home 732-3241

LOCATION 150 west from end of road at end of SR 1221 trailer on left S. R. No.

SUBDIVISION NAME Lake Norman LOT NO. 23 SECTION OR BLOCK NO. 10


House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	( )	No	(✓)
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area Adequate

Character & Porosity of Soil Clay loam, porosity good
Percolation Rate 20" after water
Topography 2 to 3% Slope
Depth to Water Table 10'
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 720 Linear Ft. 360
Depth of Stone in Lines 11"
Water Supply: Individual (✓)
Public ( )
Well west side

Installed by Tarco
Plumbing Contr.
Statesville, N.C.

IMPROVEMENTS PERMIT BY J. C. Mount

COMMENTS:

CERTIFICATE OF COMPLETION BY J. C. Mount DATE 7-20-05

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold