DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: part of 2PC-15
PROPERTY RECORDED: Y/S
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Bob Fineberg for Paul Bigelow OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: 11/23/93 DATE EVALUATED: 11/23/93
PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE:
LOCATION OF SITE: lot 45, Whippoorwill Woods
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LS	0-7"	gr / SL	1:1 / vfr	–	–	PS	–	.6
		7-14"	gr / scl	1:1 / fr	–	–	PS	–	.5
		14-28"	SAB / C	1:1 / fi	–	–	PS	–	.4
		28-41"+	WK SAB / scl	1:1 / fi-vfi	–	–	PS	–	.4
2									
3									
4									
5									

AVAILABLE SPACE (.1948): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .4
EVALUATED BY: DWilson OTHER(S) PRESENT: Bob Fineberger
COMMENTS: