DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____OF_____
PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

# SOIL/SITE EVALUATION
## FOR
## ON-SITE WASTEWATER SYSTEM

APPLICANT: Joel Herberg OWNER:__ AGENT:__ PHONE:_____
ADDRESS:_____ APPLICATION DATE:_____ DATE EVALUATED: Dec 13, 93
PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE:_____
LOCATION OF SITE: Lot 26 / Huguenot Woods
WATER SUPPLY: On-Site Well ✓ Comm. Well__ Public___ Other_____ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

| PROFILE # | .1940 LANDSCP POS. (%) | HORIZON DEPTH (IN.) | .1941 STRUCTURE/TEXTURE | .1941 MINERALOGY/ CONSISTENCE | .1942 WETNESS COND. | .1944 RESTRICT HORIZONS | .1948 CLASS OF HORIZ | 1943/ 1956 SAPRLT CLASS. | HORIZON LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | LS | 0-13 | SA6 / cL | 1:1 / fr | — | — | PS | — | .5 |
| | | 13-39 | SA6 / C | 1:1 / fi | — | — | PS | — | .4 |
| | | 39+ | wkSA6 / sicl | 1:1 / vfi | — | — | PS | — | .25 |
| 2 | | | | | | | | | |
| 3 | | | | | | | | | |
| 4 | | | | | | | | | |
| 5 | | PS | | | | | | | |

AVAILABLE SPACE (.1945): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .4
EVALUATED BY: DB Thomas OTHER(S) PRESENT: Joel Herberg
COMMENTS: trenches should be installed at 24" trench bottom depth