4637364458

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hugh- Gilbert Abernathy DATE 7-28-75 PERMIT NO. _____

PHONE: Business _____ Home 664-5707

LOCATION 150 west TR on 1180 at end TR on 1221 at end S. R. No. 1221

SUBDIVISION NAME Lake Norman LOT NO. 14 SECTION OR BLOCK NO. _____
Hidden Cove

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 2 acre

Character & Porosity of Soil Sandy Clay Porosity +-
Percolation Rate Not taken
Topography 2 to 3% Slope on lot
Depth to Water Table 10'+
Rock or other impervious formations None Encountered

Lake Norman Hidden Cove



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 24"
Water Supply: Individual (✓)
Public ( )
10' storm away from line
Installed by _____

New Deck 6.22.10

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: replaces Permit issued on 7-25-75. Bought another lot

The proposed / existing Deck addition does not appear to impact the existing septic system.
**NOTE: _____

CERTIFICATE OF COMPLETION BY Judy Melville REHS DATE 6-22-10
Date: 6-22-10
ICHD-Environmental Health Division

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

See completion signed next page

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold