DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: N. Wade APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 9-10-02
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 45 Sec 2 Edgewater PL PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	9% S	0-7	gr fr vfr sl	fr sss sp vp					.3
		7-28	m sbk rc	fr s sp s p					
		28-53	(B-C) w f m sbk gr l	fr sss p	Low in clay & wetness				
2		0-4	gr fr vfr sl	fr sss p					.3
		4-25	m sbk rc	fr s sp s p					
		25-36	w f sbk gr cl	fr sss p	Low in clay				
3		0-8	gr-w f sbk & gr vfr sl	fr sss p					.3
		8-36	m sbk rc cl	fr ss s sp					
		36-52	(B-C) w f sbk gr cl	fr ss p					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	R	R
System Type(s)	Gravity 25% Red	Gravity 25% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): R
EVALUATED BY: [signature]
OTHER(S) PRESENT: Wendell Chambers