DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Niblock — APPLICANT: _____
ADDRESS: _____ — APPLICATION DATE: _____ — DATE EVALUATED: 9-10-09
PROPOSED FACILITY: SFR — PROPOSED DESIGN FLOW (.1949): 480 gpd — PROPERTY SIZE: _____
LOCATION OF SITE: Lot 46 Sec 2 Edgewater JR — PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTA
1		0-4	gr brn sl/scl	fr sss sp					.3
		4-10	m sbk rc	fr ss/sst sp					
		10-24	wk sbk rcl	fr ss sp					
		24-48	(B-C) wk sbk rcl/l	fr ss sp	common mica/sap				
2		0-6	gr brn sl	fr ss sp					.25 / .3 > 30"
		6-11	wk sbk brn sl	fr ss sp					
		11-30	wk-m sbk rc	fr ss/st sp					
		30-54	(B-C) wk sbk rcl/l	fr ss sp	common mica/sap				
3		0-9	gr brn scl/sc	fr ss/st sp					.3
		9-34	m sbk rc	fr ss/st sp					
		34-53	(B-C) wk sbk rcl/l	fr ss sp	common mica/sap				
4	9% +/- s/l	0-6	gr brn sl	fr ss sp					.3
		6-15	gr-wk sbk brn sl	fr ss sp					
		15-28	wk sbk brn cl	fr ss sp					
		28-50	m sbk rc	fr ss/st sp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	RS	RS
System Type(s)	Conv 25% Red	
Site LTAR	.3	.25-.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): RS
EVALUATED BY: _____
OTHER(S) PRESENT: Wastewater Inspector