DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: N. Block — APPLICANT: ____
ADDRESS: ____ — APPLICATION DATE: ____ — DATE EVALUATED: 9-10-9
PROPOSED FACILITY: SFR — PROPOSED DESIGN FLOW (.1949): 480 gpd — PROPERTY SIZE: ____
LOCATION OF SITE: Lot 47 Sec 2 Edgewater Pk — PROPERTY RECORDED: ____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTA
1		0-6	gr brn sl	fr sss p					
		6-41	mk sbk	fr ss p	few common manganese coatings				.25-.3
		41-54	wk sbk	fr ss p	common mn stn				
			(B-C)						
2	Bot S	0-4	gr brn sl	fr sss p					
		4-22	mk sbk	fr ss p					.3
		22-54	(B-C) wk sbk	fr ss p	common mn stn				
3		0-5	gr brn sl	fr sss p					
		5-16	wk sbk	fr ss p	stn				.3+
		16-36	wk sbk	fr ss p	stn				
		36-54	wk sbk	fr ss p					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	GRW 25%	GRW pumped 15%
Site LTAR	.3	.25-.3

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DR Thomas
OTHER(S) PRESENT: Wendell Crumbley