8955

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Julian D'Amico DATE 6/17/88 PERMIT NO. _____

PHONE: Business _____ Home 366-5899

LOCATION 1100 TR Oak Tree TL Oak Tree Near end on R. S. R. No. _____

SUBDIVISION NAME CL&T LOT NO. ~~9~~ 205 (1497) SECTION OR BLOCK NO. ~~2059~~ 9 (~~1497~~)


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clayey
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	~~1.4~~ gpd/ft²
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	290
Site Suitable D.S.	Yes ( )	No ( )	Depth to Water Table	4'+
			Rock or other impervious formations	none observed.

Lot Area .65 ACRE 20,000 ft²+

Basement with Plumbing ST. Basement without Plumbing ✓ No Basement P.T. 1250



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Julian D'Amico, Jr.

IMPROVEMENTS PERMIT BY Andrew C. Quinn

COMMENTS: Install tanks 50'+ from lake. 2" Sch 40 PVC pipe line to each ditch. Ball valve at each ditch. 2' pressure head on each. High water alarm to be installed on separate circuit. Holes in solid pipeline (1½") of drainfield should be 5/32" and spaced 5' apart. Keep ditch level and on contour.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold