DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Jerome Watson
ADDRESS: _____ APPLICATION DATE _____
PROPOSED FACILITY: Residential PROPOSED DESIGN FLOW (.1949): ~~480~~ 360 DATE EVALUATED: 6-7
LOCATION OF SITE: 150 Th Doolie TR Whiteville PROPERTY SIZE: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☒ Auger Boring ☒ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	AH 8%	0-10	1sbk cl			48			PS .3
		10-36	1sbk c	fr ss/sp/se					
		36-48	c+sap						
2	AH 16%	0-8	1sbkcl			48			PS .3
		8-48	1sbk c						
Pit 3	in gravel drive	7-0	fill			48			PS .3
		0-11	1sbk cl						
		11-30	1sbk c	fr ss/sp/se					
		30+48	c+sap						
Pit 4	5' from house 10' from septic water line	8-0	fill						
		0-35	1sbkcl						
		35	1sbkcl+sap		inc. chroma 2				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	yes 3 bd.	yes 3 bd
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: J Melville
OTHER(S) PRESENT: _____
COMMENTS: _____