DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Danny Gabriel OWNER: AGENT: PHONE: ___
ADDRESS: PO Box 55 APPLICATION DATE: ___ DATE EVALUATED: 3/14/94
Sherrills Ford, NC PROPOSED FACILITY: 3 bedroom SF dwelling
PROPERTY SIZE: ___
LOCATION OF SITE: lot 23, Whippoorwill
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LS	0-19	gr-SAB / scL	1:1 / fR	2	2	PS	2	.5
		19-46+	SAB / C	1:1 / vfi					.3
2	LS	0-11	gr / scL	1:1 / fR	2	2	PS	2	.5
		11-18	SAB / CL	1:1 / fr-fi					.4
		18-42	SAB / C	1:1 / vfi					.3
		42+	wk SAB / CL	1:1 / fi					.3+
3									
4									
5									

AVAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1948) PS SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: [illegible] OTHER(S) PRESENT: Danny Gabriel
COMMENTS: ___