DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

# SOIL/SITE EVALUATION
## FOR
## ON-SITE WASTEWATER SYSTEM

APPLICANT: Danny Gabriel OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: June 7, '94
PROPOSED FACILITY: 3 bedroom SF dwelling
PROPERTY SIZE: ca 3/4 Ac.
LOCATION OF SITE: lot 31, Pepperwell Woods
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

| PROFILE # | .1940 LANDSCP POS. (%) | HORIZON DEPTH (IN.) | .1941 STRUCTURE/TEXTURE | .1941 MINERALOGY/ CONSISTENCE | .1942 WETNESS COND. | .1944 RESTRICT HORIZONS | .1948 CLASS OF HORIZ | 1943/ 1956 SAPRLT CLASS | HORIZON LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | LS-SS 4-6% | 0-8" | gr-scl | 1:1/fr | | | PS | | .5 |
| | | 8-29" | SAB-c | 1:1/fi | | | PS | | .4 |
| | | 29-48 | wkSAB-sic | 1:1/fi | | | PS | | .3 |
| 2 | LS-SS 4-6% | 0-6" | gr-scl | 1:1/fr | | | PS | | .5-.6 |
| | | 6-30" | SAB-c | 1:1/fi | | | PS | | .3 |
| | | 30-48" | wkSAB-sic(B/C) | 1:1/fi | | | PS | | .3 |
| 3 | | | | | | | | | |
| 4 | | | | | | | | | |
| 5 | | | | | | | | | |

AVAILABLE SPACE (.1945): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: [signature] PS OTHER(S) PRESENT: Danny Gabriel
COMMENTS: numerous scattered surface rock within 1 foot of ground surface.