DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 2214A 18
PROPERTY RECORDED: YES
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Frances Robinson
ADDRESS: _____ OWNER: _____ AGENT: _____ PHONE: _____
APPLICATION DATE: _____ DATE EVALUATED: Dec 9, '93
PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE: 1.023 Ac
LOCATION OF SITE: Lot 18, Whippoorwill Woods
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	SS	0-2"	gr - SL	1:1 / Vfr	—	—	PS	—	.5
		2-26"	SAB / C	1:1 / fi	—	—	PS	—	.5
		26-48"	SAB(w) sicl	1:1 / fR	—	—	PS	—	.5
2									
3									
4									
5									

AVAILABLE SPACE (.1945) PS? SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .63
EVALUATED BY: [illegible], RS OTHER(S) PRESENT: Jeana Duckworth
COMMENTS: Site very dense with vegetation. Realtor/owner given option of partially clearing site in order to evaluate it for a conventional system. They opted for a PPBPS instead. DH