2:45

IREDELL COUNTY HEALTH DEPARTMENT

07473

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Laura Parker DATE Oct 7 87 PERMIT NO.

PHONE: Business Home

LOCATION 150 W to Oodie Road to R Whippoorwill 1st lot on left S. R. No.

SUBDIVISION NAME CLFT Lake Norman LOT NO. 1167 SECTION OR BLOCK NO.

Future Temporary


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	2.4	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	10-25%	
Site Suitable	Yes ( )	No ( )	Depth to Water Table	4ft	
			Rock or other impervious formations	none obs.	

Lot Area ~2 AC

___ Basement with Plumbing ___ Basement without Plumbing ___ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 700 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed Laura Parker

Whippoorwill (1221)

ROAD ACCESS

IMPROVEMENTS PERMIT BY D. Hanson RS.

COMMENTS: Follow contour with drainfield, install drainfield at a depth of 30" to bottom of ditch. Use drop boxes to distribute effluent.

CERTIFICATE OF COMPLETION BY DATE

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold