DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____OF_____
PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jan Fuquay OWNER:__AGENT:__ PHONE:_____
ADDRESS:_____ APPLICATION DATE:_____ DATE EVALUATED: 12/27/94
_____ PROPOSED FACILITY: 360 gpd
_____ PROPERTY SIZE: 2 ac
LOCATION OF SITE: lot 3
WATER SUPPLY: On-Site Well____Comm. Well___Public___Other_____EVAL. METHOD: Auger Boring ✓ Pit___Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-5	gr-scl	1:1 fri					.35
		5-12	sbk cl	1:1 fi					
		12-45+	sbk-c	1:1 fi					
2		0-4	gr-scl	1:1 vfr	wet				.3
		4-30	sbk c	1:1 fi					
		30-45+	wk sbk cl	1:1 fi, ss					
3									
4									
5									

AVAILABLE SPACE (.1945)_____ SITE CLASSIFICATION (.1948):_____ SITE LONG-TERM ACCEPTANCE RATE: .35

EVALUATED BY:_____ OTHER(S) PRESENT:_____

COMMENTS:_____