DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH


SHEET____OF_____
PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jon Gregorian OWNER:__AGENT:__ PHONE:_____
ADDRESS:_____ APPLICATION DATE:_____ DATE EVALUATED:_____
PROPOSED FACILITY:_____
PROPERTY SIZE:_____
LOCATION OF SITE: Lot 17 / Whispering Pines
WATER SUPPLY: On-Site Well___ Comm. Well___ Public___ Other_____ EVAL. METHOD: Auger Boring___ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
Pit 1		0-3	SCL gr	1:1					.3
		3-20	C SSAB						
		20-36	Cl SAB	1					
		36-48	Cl vw SAB	1:1					
2 Pit		0-17	C SSAB	1:1					.3
		17-29	Cl SAB	1					
		29-42+	Cl WSAB						
3									
4									
5									

AVAILABLE SPACE (.1945)_____ SITE CLASSIFICATION (.1948):_____ SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: WK OTHER(S) PRESENT: TGrotte
COMMENTS: Keep trenches shallow


出口
折り目
出口