IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PROPERTY DESCRIPTION NO. 18197 DATE March 1, 195 TAX MAP NO. part of 2PC15 4637 57 1251 Watershed: ☑ Yes ☐ No

OWNER OR CONTRACTOR Genesis Dev. Ltd. / Jim Gregorian PHONE: Business 664-3400 Home WSIV

ADDRESS PO Box 414 Shelby Fold, NC 28673

LOCATION 150' W of Deare Road off Purple Finch Lane at end

SUBDIVISION Thoroughwood Woods BLOCK / SECTION 2 LOT 10 LOT AREA 52,000 ft² SITE CLASS PS per 1996 DESIGN FLOW 480 gpd L.T.A.R. .03

Septic Tank: 1500 Gallons; STB 797 Date 11/19/96

Pump Tank: 1500 Gallons; PT 797 Date 9/16/96

Pump Make: HYDROMATIC Model SK50A1 Serial No. none

Nitrification Field: No Fields / Square Feet ____ Linear Feet 400

No Lines 4 Trench Width 36" Max Trench Bottom Depth 30" Gravel Depth N/A

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: pump / Infiltrator Cateeds

Repair System Description: LP PPBPS / LDP

Maintenance Agreement Required: ☐ Yes ☑ No initially

☐ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other Duplex

No. Bedrooms 4 No. Bathrooms 2 No. Employees ____

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Community ☐ Public

Comments: Well serving this site at rear of lot 2.
Cateeds to follow contours

Comments: TANKS, LINES, PRESSURE CHECKED 3/11/97
DEVELOPER PERMIT

1" = 100'

INITIAL SITE SKETCH

4" sch 80 pressure manifold 4 (½") trips 6" oc

LP PPBPS Repair Area

Slope Change LP Pressure Line

Duplex

Parking

Water Line

Well 100' 23' Infiltrator Cateeds

AS BUILT SKETCH

SAME AS SITE SKETCH

I understand that this permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date of issuance.

Signed: [signature] CHIEF Agent

Improvement Permit by: [signature] date 3/1/95

Existing System Inspection by: [signature] date 10/31/96

Installed by: LEVON BENTON

Certificate of Completion by: Wesley Sparks R.S. date 4/15/97

Operation Permit by: Wesley Sparks R.S. date 4/15/97

Authorization to Construct

DEPT. COPY: WHITE INSPECTION COPY (FINAL): GREEN OWNER COPY (FINAL): YELLOW INSPECTION COPY (INITIAL): PINK OWNER COPY (INITIAL): GOLD