IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Billy Howe DATE 2-13-20 PERMIT NO. 249

PHONE: Business _____ Home _____

LOCATION 150 West Fork on 1002 Fork 1002 Fork 1002, 4 mi on Lazy

S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 2 acres

Character & Porosity of Soil Sandy Clay loam bed rock
Percolation Rate 45 min per inch
Topography Gently sloping
Depth to Water Table 18"
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 225 Linear Ft. 250
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Mark Scott Fork Co

IMPROVEMENTS PERMIT BY Billy Howe

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Billy Howe DATE 2-13-20

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold