4637806478

12588

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR H.C. Needham / Bowman & Dev. Co. DATE Oct. 2, '91 PERMIT NO. 2K-21-A-5

PHONE: Business _____ Home _____

LOCATION 1100 past Brawley School TR just past D+G Mart II

S. R. No. _____

SUBDIVISION NAME Promenade Com. Center LOT NO. 5 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Duplex Apt 480 gpd design flow

Total

No. Bedrooms 4 No. Bathrooms 4

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site ~~Suitable~~ PS Yes (✓) No ( )

Lot Area 30,000 ft²

Character & Porosity of Soil sl clay


Percolation Rate 40, 3 0

Topography 2%

Depth to Water Table 4'+

Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 1602 Linear Ft. 534

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Ray Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY D.R. Hinson, RS. DATE 10-27-91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold