09649

4637-90-8014

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Lance Sheim DATE May 19, 89 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 TL Farmstead Lane on Right at corner of Farmstead Lane and Perennial Drive S. R. No. _____


SUBDIVISION NAME Farmstead LOT NO. 29 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site ~~Suitable~~ PS Yes (✓) No ( )
Lot Area ±115'x235'

Character & Porosity of Soil Clay
Percolation Rate ~35
Topography 2-4%
Depth to Water Table 4'
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System FARMSTEAD LANE

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 24"
Water Supply: Individual (✓)
Public ( )

Installed by Roy Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Well not down. House foundation not started. Owner decided to set larger tank.

CERTIFICATE OF COMPLETION BY David R. Hunter, R.S. DATE 5-19-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold