4038016628

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

383

OWNER OR CONTRACTOR Scott Thomas DATE 10/31/79 PERMIT NO. [redacted]

PHONE: Business _____ Home _____

LOCATION 150W TR on 1438 Blue Rt. on 1450 ~½ mi on Rt. S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 236 SECTION OR BLOCK NO. 11

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area .8 AC.


Character & Porosity of Soil Clay loam

Percolation Rate 80 mpi

Topography 25 - 35%

Depth to Water Table unk.

Rock or other impervious formations more than 4 ft.



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 750 Linear Ft. 250

Depth of Stone in Lines 16"

Water Supply: Individual (✓)

Public ( )

Installed by J.R. Bowles

IMPROVEMENTS PERMIT BY H.R. Hanson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Harold R. Hanson DATE 10/31/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold