IREDELL COUNTY HEALTH DEPARTMENT 4638018231

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR C. H. Reynolds DATE 10-9-80 PERMIT NO. 314

PHONE: Business _____ Home _____

LOCATION 150W TR 1438 Barn Rt. 1450 1/4 - 1/2 mi. TR dirt rd. on left S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 228 SECTION OR BLOCK NO. 11

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area .84 Ac.

Character & Porosity of Soil clay loam
Percolation Rate 80 min/in
Topography 4-6%
Depth to Water Table mark. 6'+
Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16" +
Water Supply: Individual (✓)
Public ( )

Installed by O. L. Parker

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY JHC

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Gleason DATE 10-9-80

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold