IREDELL COUNTY HEALTH DEPARTMENT 4638019306

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Alton E. Mitchell DATE 7-2-80 PERMIT NO. 190

PHONE: Business _____ Home _____

LOCATION 150 (+) TR 1438 TR 1450 1st Road to R (Ross Road) Near end on left L Norman S. R. No. _____


SUBDIVISION NAME _____ LOT NO. 227 SECTION OR BLOCK NO. 4

House ( ) Mobile Home (X) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Sandy loam	Porosity good
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	50 mpi	
Auto. Wash. Machine	Yes (X)	No ( )	Topography	20%	
Site Suitable	Yes (X)	No ( )	Depth to Water Table	8'-10'	
Lot Area	3/4 Acre Lake		Rock or other impervious formations	None observed	

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field: 3
No. of Lines
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (X)
Public ( )

Installed by 4-23-76 Sam Oswalt

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Existing system working ok at date of inspection - Never connected to sewer system

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Fred Clemmer DATE 7-2-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold