10206

4638023158

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Joseph R. Howell DATE Mar 15, 1990 PERMIT NO. 2N-3-A-240

PHONE: Business _____ Home _____

LOCATION 150 W TR Waddell Rd. TR Hermance Rd. On right just before Golden Pond S. R. No. _____

SUBDIVISION NAME CL+T Lake Norman LOT NO. 240 SECTION OR BLOCK NO. 11

House ( ) Mobile Home (✓) DW Business ( ) Other Relayout to conventional system MH reduced to 2 Bdr

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site ~~Suitable~~	Yes (✓)	No ( )

Lot Area ~3/4 ac

Character & Porosity of Soil fs cly


Percolation Rate ~.3

Topography ~8%

Depth to Water Table 4'+

Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 825 Linear Ft. 275'
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Cline + Gilleland

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Sam Ingram EH&S DATE Mar 15, 1990

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

This is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold