IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James M. Capps DATE 4-8-76 PERMIT NO. 71

PHONE: Business 332-3609 Home 528-0727

LOCATION 50 W TR on 3396 Lai on Left

S. R. No. 11

SUBDIVISION NAME Lake Norman LOT NO. 205 SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area ½ acre


Character & Porosity of Soil Sandy Clay loam Fair Boring

Percolation Rate Not Taken

Topography 20% Slope

Depth to Water Table 10'

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Sam Stuart

IMPROVEMENTS PERMIT BY John Houston

COMMENTS:

CERTIFICATE OF COMPLETION BY John Houston DATE 4-7-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold