DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 9-28-98
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 8, Robinson Woods PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-4	SK congested rd/brn l sl			11			
		4-22	Mod wk sbk l sl	fr sso fr fpss					
			Stone lite. 1/4"						
2		0-23	sgl rd/brn l sl	fr sso					
		23-52	wk sbk mod yr rd/brn sl	fr sso/ fr sso					
		52-69	mas l sap	fr sso		12			
			Lens wh fine sand						
3		0-8	lam sl						PS .3
		8-22	sgl, mc	fr sso					
		22-52	wk lam rd/brn sl	fr sso					
			Lens wh sand						
4	10-5-98	0-4	wk sbk mr sl	fr					PS .3
		4-22	sgl rd/gl	fr sso sap					
		22-48	wk sbk yr cl	fr ss sp					
			lens common sand						
#5		0-14	sgl rd/gl	lens wh sand	14-45 wk sbk yr cl	lens common med fine sap;	45-48 sap cl		PS .3

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____