4638047569

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Homer Friday DATE 10-9-80 PERMIT NO. 315

PHONE: Business _____ Home _____

LOCATION 150 W. TR 1396 ± 1 mi. on Left

S. R. No. _____

SUBDIVISION NAME L.N LOT NO. 187 SECTION OR BLOCK NO. 11

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay Loam
Percolation Rate 8 Imp. ft.
Topography 15% - 25%
Depth to Water Table 4 mt.
Rock or other impervious formations none obs.

Lot Area .68 ac.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. ~750 Linear Ft. ~250
Depth of Stone in Lines 18 - 20"

Water Supply: Individual (✓)
Public ( )
Well next Door

Installed by F. J. Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY FPC

COMMENTS: drainfield only 60' long and varied in width from 10-15'. Extra stone used to make up for footage.

CERTIFICATE OF COMPLETION BY Howard K. Hinson DATE 10-9-80

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold