9383

4658-07-4607

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Eric Ferguson Laura Ferguson DATE 12/30/88 PERMIT NO. 17 D

PHONE: Business _____ Home _____

LOCATION 1303 N. TL 1300 (Fern Hill) near end - across from Broadview Loop 108 = Co. # S. R. No. _____

SUBDIVISION NAME L. N. LOT NO. 1082 SECTION OR BLOCK NO. 15

Tax # 3C-10-A-108


House (✓) Mobile Home ( ) Business ( ) Other _____

*Info from completion of 11-13-86 DRH

| | | | | | |
|---|---|---|---|---|---|
| No. Bedrooms | 3 | No. Bathrooms | 2 | Character & Porosity of Soil | clayey |
| Garbage Disposal Unit | Yes ( ) | | No (✓) | Percolation Rate | .4 gpd/ft² |
| Auto. Dishwasher | Yes (✓) | | No ( ) | Topography | 15-25% |
| Auto. Wash. Machine | Yes (✓) | | No ( ) | Depth to Water Table | 4'+ |
| Site Suitable | Yes (✓) | | No ( ) | Rock or other impervious formations | none observed |

Lot Area 20,000ft²

(✓) Basement with Plumbing _____ Basement without Plumbing _____ No Basement 1000 gal PT.




Plot of System STREET

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by F.J. Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: System installed and inspected 11-13-86. No sign of malfunction at this date. (drainfield is dry)

Homeowner:
(*) This would be a good time to check/regulate the flow to the drainfield. Call me if you have any questions.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Andre C. Pena DATE 12/30/88

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

